



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing



ANALYTICAL RESULTS

STANDARD DELIVERABLES FORMAT

APL WORK ORDER NUMBER: 7060334

Newmark Education

Project: Newmark Education

Brian Wood
Laboratory Director

All Results meet the requirements of the National Environmental Laboratory Accreditation Conference and/or
State specific certifications as applicable.



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

Newmark Education

Client: Newmark Education

Contact:

APL Order ID: 7060334

Received: 06/09/17 12:40

Sample ID/Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
7060334-01 (Drinking Water)		Water Cooler Cafe		Collected:	06/09/17 05:20			
Total Metals								
Lead	EPA 200.8	06/13/17 13:23	06/13/17 13:23	ND		0.00200		mg/L
7060334-02 (Drinking Water)		Water Fountain Cafe		Collected:	06/09/17 05:30			
Total Metals								
Lead	EPA 200.8	06/13/17 13:27	06/13/17 13:27	ND		0.00200		mg/L
7060334-03 (Drinking Water)		Water Cooler Office		Collected:	06/09/17 05:40			
Total Metals								
Lead	EPA 200.8	06/13/17 13:32	06/13/17 13:32	ND		0.00200		mg/L
7060334-04 (Drinking Water)		Water Fountain Gym		Collected:	06/09/17 05:45			
Total Metals								
Lead	EPA 200.8	06/13/17 13:36	06/13/17 13:36	ND		0.00200		mg/L
7060334-05 (Drinking Water)		Water Fountain Elem. Hall		Collected:	06/09/17 05:50			
Total Metals								
Lead	EPA 200.8	06/13/17 13:40	06/13/17 13:40	ND		0.00200		mg/L
7060334-06 (Drinking Water)		Water Cooler Teacher's Cafe		Collected:	06/09/17 06:00			
Total Metals								
Lead	EPA 200.8	06/13/17 13:45	06/13/17 13:45	ND		0.00200		mg/L
7060334-07 (Drinking Water)		Water Fountain High School		Collected:	06/09/17 06:15			
Total Metals								
Lead	EPA 200.8	06/13/17 13:49	06/13/17 13:49	ND		0.00200		mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns.
H - Indicates a Hold Time violation